

UDISE CODE. 06150101403

SCHOOL EMAIL: principalgss3079@gmail.com

PM SHRI GOVT. SENIOR SECONDARY SCHOOL

DADRI TOYE-124103, JHAJJAR (HARYANA)


(SCHOOL CODE : 3079)

Ref.No.....348.....

DATE 28-06-2025

उपक्रम (Undertaking)

प्रमाणित किया जाता है कि
महानिदेशक, हरियाणा अग्निशमन सेवाएं,
पंचकुला के पत्रांक FS/2024/1534
दिनांक 28/11/2024 के अनुसार विद्यालय
को Fire Fighting Scheme Approved
हो चुकी है और Fire Fighting Scheme
fitting संबंधी कार्य under process है।
विभाग से जैसे ही NOC प्राप्त होगा, शीघ्रता
शीघ्र NOC submit करा दिया जाएगा।


Principal
P.M. Shri Govt. Sr. Sec. School
DADRI TOYE (Jhajjar)-3079
28/06/2025

From Director General

Fire Service, Haryana Panchkula

To M/s P M SHRI GOVT MODEL SANSKRITI SR SEC SCHOOL
VILLAGE DADRI TOYE TEHSIL BADLI DISTRICT JHAJJAR

Memo No. FS/2024/1534 dated : 28/11/2024

Subject : Approval of fire fighting scheme Under 15 mtrs. from the fire safety point of view for Group B-Educational Building at VILLAGE DADRI TOYE TEHSIL BADLI DISTRICT JHAJJAR of P M SHRI GOVT MODEL SANSKRITI SR SEC SCHOOL :

Reference your Transaction Id 071432423000136 dated: 28/11/2024 on the subject cited above.

Your case for the approval of fire fighting scheme has been examined by the team of Fire Station Officers, Bahadurgarh Main, .The means of escape and Fire Protection system were checked and found as per the National Building Code of India, Part- IV guidelines. Therefore your proposed fire fighting scheme is hereby approved as per following detail from the fire safety point of view with the following conditions:-

| Tower Name | Floor Detail | Terrace Height of Last Livable Floor(In Meters) | Ground Coverage |
|-------------------|-----------------------|--|-------------------------|
| Block 1 | GF | 3.96 mtrs | 873.66 SQM |
| Block 2 | GF | 3.96 mtrs | 139.35 SQM |
| Block 3 | GF | 3.96 mtrs | 502.43 SQM |
| Block 4 | GF | 3.96 mtrs | 104.23 SQM |
| Block 5 | GF | 3.96 mtrs | 59.23 SQM |
| Block 6 | GF | 3.96 mtrs | 18.9 SQM |
| Block 7 | GF | 3.96 mtrs | 18.9 SQM |
| Block 8 | GF | 3.96 mtrs | 16.5 SQM |
| Block 9 | GF | 3.96 mtrs | 10.43 SQM |
| Block 10 | GF | 3.96 mtrs | 13.35 SQM |
| Tower Name | Basement Level | Basement Area | Basement Remarks |
| | NA | NA | NA |

- 1) The proposed fire fighting scheme is approved as submitted in the building plan subject to the approval of building plan by the competent authority.
- 2) The approval of fire scheme by this office doesn't absolve the firm from his responsibility from all consequences, in case of fire due to any deficiencies or anything left out in the scheme submitted by you.
- 3) Overhead & underground water tanks provided for firefighting shall be so constructed in such a way that the domestic water tank shall filled from overflow of the fire Water tanks.
- 4) As soon as the installations of fire fighting arrangements are completed, the same may be got inspected/ tested and clearance should be obtained from this office.
- 5) If the infringement of Byelaws remains un- noticed the Authority reserves the right to amend the Plans/Fire Fighting Scheme as and when any such infringement comes to notice after giving an opportunity of being heard and the Authority shall stand Indemnified against any claim on this account.
- 6) If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009 i.e. imprisonment for a term which may extend to three month or fine which may extend to five thousand rupees or both.
- 7) The staircase shall be made with the specified material enabling it non-slippery.
- 8) The above Fire Fighting Scheme is valid for Two Year from the date of issue of this letter.
- 9) If the gap between ceiling and false ceiling is more than 800 mm then upright sprinkler and detectors above false ceiling & pendent sprinkler below false ceiling shall be installed in the building

Deputy Director (Technical)-I,
for Director General, Fire
Service, Haryana



Panchkula

Exercising the power of Director, Fire Services, Haryana



Digitally signed by GULSHAN
KALRA
Date: 2024.11.28 16:11:39 +05:30
Reason: Digital Verification

Performa for Haryana Fire Service

10

| | | |
|----|---|--|
| 1. | a. Name of the Building | PM SHRI GOVT. SR.SEC.SCHOOL |
| | b. Address of the Building | Village Dadri Toye Jhajjar (HR) |
| | c. Name and Address of Promoter | PM SHRI GOVT. SR.SEC.SCHOOL Village Dadri Toye Jhajjar (HR) |
| | Name & Address of owners | PM SHRI GOVT. SR.SEC.SCHOOL Village Dadri Toye Jhajjar (HR) |
| 2. | Type of Occupancy | Educational Building Group - B |
| 3. | No. of Block / Tower | 10 Block |
| 4. | Height of Building | Block 1 - 3.96 M Block 2 - 3.96 M Block 3 - 3.96 M Block 4 - 3.96 M Block 5 - 3.96 M Block 6 - 3.96 M Block 7 - 3.96 M Block 8 - 3.96 M Block 9 - 3.96 M Block 10 - 3.96 M |
| 5. | Permissible Height | 30 M |
| 6. | No. of Floor | Block 1 - Ground Floor only Block 2 - Ground Floor only Block 3 - Ground Floor only Block 4 - Ground Floor only Block 5 - Ground Floor only Block 6 - Ground Floor only Block 7 - Ground Floor only Block 8 - Ground Floor only Block 9 - Ground Floor only Block 10 - Ground Floor only |
| 7. | Covered area at Ground Floor | 1756.98 Sq. Mtr |
| 8. | Typical Floor Area / area at each floor | Block 1 Ground Floor - 873.66 SQM Block 2 Ground Floor - 139.35 SQM Block 3 Ground Floor - 502.43 SQM Block 4 Ground Floor - 104.23 SQM Block 5 Ground Floor - 59.23 SQM Block 6 Ground Floor - 18.9 SQM Block 7 Ground Floor - 18.9 SQM Block 8 Ground Floor - 16.5 SQM Block 9 Ground Floor - 10.43 SQM Block 10 Ground Floor - 13.35 SQM |
| 9. | No. of Basement | No Basement |

Certified that this Fire Fighting Scheme Drawing
is as per NBC, 1983 Part-IV Revised 2016

[Signature]
JHAJJAR

[Signature]
JHAJJAR

[Signature]
Principal,
Govt. Sr. Sec. School
DADRI TOYE (H.R.)

[Signature]
TARUN KUMAR
Fire Consultant
Graduate Member
Institution of Fire Engineers (India)
M. HUDA Complex, Rastak
Ph. 9218028491